

| SDR-21 SOLVENT WELD RECLAIMED WATER PIPE 200 PSI PVC1120 ASTM D2241 | SIZE | O.D. | MIN. WALL | WEIGHT PER 100' | SOCKET DEPTH INCHES | FEET PER PALLET | PALLETS PER T.L. | BELLED PART NO. |
|--|-------|------|--------------|-----------------------|---------------------------|-----------------------|------------------------|-----------------------|
| | *1/2" | .840 | .062 | 9.81 | 2.000 | 8400 | 44 | 57015 |
| 3/4 | 1.050 | .060 | 12.11 | 2.125 | 6600 | 40 | 57030 | |
| 1 | 1.315 | .063 | 16.17 | 2.375 | 5400 | 32 | 57045 | |
| 1 1/4 | 1.660 | .079 | 25.59 | 2.750 | 4000 | 32 | 57055 | |
| 1 1/2 | 1.900 | .090 | 33.32 | 3.000 | 3600 | 28 | 57070 | |
| 2 | 2.375 | .113 | 52.32 | 3.000 | 2800 | 24 | 57085 | |
| 2 1/2 | 2.875 | .137 | 76.53 | 3.500 | 2240 | 20 | 57100 | |
| 3 | 3.500 | .167 | 113.71 | 4.000 | 1500 | 20 | 57110 | |
| 4 | 4.500 | .214 | 192.22 | 5.000 | 580 | 28 | 57120 | |
| 6 | 6.625 | .316 | 420.11 | 6.500 | 400 | 20 | 57130 | |

*SDR 13.5 - 315 PSI

| SCH-40 SOLVENT WELD RECLAIMED WATER PIPE PVC1120 ASTM D1785 | SIZE | O.D. | MIN. WALL | WEIGHT PER 100' | SOCKET DEPTH INCHES | FEET PER PALLET | PALLETS PER T.L. | BELLED PART NO. |
|---|-------|-------|--------------|-----------------------|---------------------------|-----------------------|------------------------|-----------------------|
| | 3/4" | 1.050 | .113 | 21.58 | 2.125 | 6600 | 40 | 57230 |
| 1 | 1.315 | .133 | 32.00 | 2.375 | 5400 | 32 | 57245 | |
| 1 1/4 | 1.660 | .140 | 43.40 | 2.750 | 4000 | 32 | 57255 | |
| 1 1/2 | 1.900 | .145 | 51.83 | 3.000 | 3600 | 28 | 57270 | |
| 2 | 2.375 | .154 | 69.71 | 3.000 | 2800 | 24 | 57285 | |
| 2 1/2 | 2.875 | .203 | 110.57 | 3.500 | 2240 | 20 | 57300 | |
| 3 | 3.500 | .216 | 144.82 | 4.000 | 1500 | 20 | 57310 | |
| 4 | 4.500 | .237 | 211.35 | 5.000 | 580 | 28 | 57320 | |

| SDR-21 GASKET JOINT RECLAIMED WATER PIPE 200 PSI PVC1120 ASTM D2241 | SIZE | O.D. | MIN. WALL | WEIGHT PER 100' | SOCKET DEPTH INCHES | FEET PER PALLET | PALLETS PER T.L. | BELLED PART NO. |
|--|-------|-------|--------------|-----------------------|---------------------------|-----------------------|------------------------|-----------------------|
| | *3" | 3.500 | .167 | 116.68 | 5.000 | 1160 | 20 | 57180 |
| *4 | 4.500 | .214 | 193.02 | 6.000 | 760 | 20 | 57187 | |
| *6 | 6.625 | .316 | 420.57 | 6.750 | 360 | 20 | 57195 | |

*20 FT. LAYING LENGTH ± 1".

GASKET JOINT PIPE IS PRODUCED WITH AN INTEGRAL BELL END WITH A REINFORCED GASKET CONFORMING TO ASTM F477.

CRESLINE RECLAIMED WATER PIPE IS PURPLE IN COLOR.



CRESLINE PLASTIC PIPE CO., INC.

www.cresline.com

600 Cross Pointe Blvd.
264 Silver Spring Rd.
2100 South 35th St.
3801 East Hwy. 31

Evansville, IN 47715
Mechanicsburg, PA 17050
Council Bluffs, IA 51501
Corsicana, TX 75109

812-428-9350
717-766-2566
712-322-2294
903-872-8475

Fax 812-428-9353
Fax 717-697-2371
Fax 712-322-6673
Fax 903-872-7732