

# SUBMITTAL SHEET

## LT-Series Lateral Tee For IPS, DPS & DIN Plastic Pipe



<b>SIZES:</b> .....	<b>2 - 12" IPS, 4 - 24" DPS &amp; 63 - 400MM DIN</b>
<b>MATERIAL:</b> .....	<b>Class 350 Ductile Iron per ASTM A-536, Grade 65-45-12, AWWA C153</b>
<b>PRESSURE RATING:</b> .....	<b>350 PSI</b>
<b>EPOXY COATING:</b> .....	<b>ANSI/AWWA C116/A21.16-09, NSF 61 &amp; CSA Z245.20-98, 10-12 MIL</b>
<b>BELL SOCKETS:</b> .....	<b>Deep slanted bell, ANSI/AWWA C116/A21.16-09, 4-lugs to accommodate joint restraints &amp; additional fittings</b>
<b>GASKETS:</b> .....	<b>High grade EPDM rubber ANSI/AWWA C111/A21.11, Rib-Enforced design</b>
<b>DEFLECTION:</b> .....	<b>5 Degrees</b>
<b>INSTALLATION:</b> .....	<b>Per IPS, DPS &amp; DIN Pipe Standards</b>

### Specification:

Fittings shall be ductile iron, slanted, deep bell, gasket style made in accordance with ASTM A-536, Grade 65-45-12 & AWWA C153. Fittings shall have four lugs to accommodate joint restraints and other fittings. Bell section shall allow 5-degree freedom of pipe deflection within the bell end. All gaskets shall be manufactured of high grade EPDM rubber and shall be rib-enforced "U-Cup" design to seal and assist in restraining pipe at all pressures. Epoxy Coating on interior & exterior surfaces of fittings shall be fusion bonded epoxy, 10-12 mil thickness. The epoxy coated fittings shall pass 90-Day immersion tests per CSA Z245.20-98. All DPS fittings shall have Epoxy Coating as standard finish. 2" LAT Bell outlet accepts Leemco lateral connections. All fittings shall be manufactured by Leemco, Inc., U.S.A.



Leemco, Inc.  
360 S. Mount Vernon  
Colton, CA. 92324  
Ph: (909) 422-0088 Fx: (909) 422-0086  
Web: www.leemco.com

Leemco has a large variety of fittings and accessories...  
Please refer to our IPS, DPS and DIN Price Lists for available Models and Sizes.